

SOCKET WELD COUPLING
NOT BY ROVANCO

FIELD APPLIED
FOAM INSULATION


FACTORY APPLIED
FOAM INSULATION

STEEL CARRIER PIPE

HDPE SPLIT MOLD

POLYETHYLENE
WRAP AROUND
SHRINK MATERIAL

HDPE JACKET



SMALL DIA. CARRIER - FIELD JOINT DETAIL

N.T.S.

Rovanco[®]

20535 S.E. FRONTAGE RD. JOLIET, IL. 60431 (815) 741-6700

NAME: 1 1/2" AND SMALLER CARRIER FIELD JOINT

APPR BY:
dk

DRAWN BY:
ad

DATE/REV:
10/26/2009

DWG NO:
FMP-SXPE-FJ-02