



SECTION A-A

RHINOLOC FRICTION ANCHOR DETAIL

N.T.S.

FOR SOME PRE-INSULATED PIPING SYSTEMS, THE EXPANSION FORCES ARE SUCH THAT THE ANCHOR STAKES AND COMPACTED BACKFILL ARE ADEQUATE TO ANCHOR THE PIPING SYSTEM. IN THESE INSTANCES, A CONCRETE ANCHOR IS NOT REQUIRED.